



Fire Safety Division

Registered by Govt of Jharkhand, 755/12-13

GLOBAL DEVELOPMENT ORGANIZATION

BC (DCP Powder) ISI : 4308 CML No. : 5522661 | ABC (Powder) ISI : 14609 CML No. : 5602760
NEW Cylinder ISI : 15683 CML No. : 5522661 | HSN/SAC No. : 84241000

FIRE SAFETY CERTIFICATE

GUARANTEE ☐ REFILLING ☒ CERTIFICATE

This is to certify that the following fire extinguishers are
refilled/supplied (New) by us

- Certificate No. GDO/JFS/MAY25/F-511
1. ABC Type : 06 Kg 01 Nos Sr No 01,02,03,04
 2. DCP Type : 10 Kg 04 Nos Sr No 01,02,03,04
 3. Mechanical Foam (AFFF) : --- Ltr. --- Nos Sr No ---
 4. CO₂ Type : 6.5 Kg 01 Nos Sr No 01
 5. Water CO₂ Type : --- Ltr. --- Nos Sr No ---
 6. Automatic Modular : --- Kg --- Nos Sr No ---
 7. Map 60 Others ---

on Dated 28-05-2025 to 27-05-2026

Certified that the MADHUSTHAL INSTITUTE OF TEACHER TRAINING,
MADHUPUR

Director PRINCIPAL at MADHUPUR

P.S. MADHUPUR, Dist. DEOGHAR PIN No. 815353

(Jharkhand) have completed with the fire prevention and fire safety
instruments requirements in accordance with fire service. Validity from

Dated 28-05-2025 to 27-05-2026



Date of Issue 28-05-2025



For Global Development Organization

Isha Kumari
Authorised Signatory

Registered Office : Lalpur, Ranchi - 834001 | Branch Office : Williams Town, Deoghar (Jharkhand)
Deals In : Fire Extinguisher Sale & Service, Hydrant System, We also provide CCTV &
Latest Safe Security Equipments, Agricultural Products & Stationery items.
Mob No. : 07549320103, email : globaldevorg@gmail.com



GLOBAL DEVELOPMENT ORGANIZATION

Fire & Safety Section

Gov of Jharkhand Reg. NO. – 755/12-13

H.O – Nangrratoli, Lalpur, Ranchi-834001

Branch Off- Williams Town B, Deoghar-814112

Mob, No.- 8340350646, Website: www.gdongo.org Email: globaldevorg@gmail.com

GSTIN: 20BZCPK1264N1ZI

Ref: GDO/JFS/MAY25/F-511

Date: 28-05-2025

TEST CERTIFICATE

This is to certify that the below mentioned Fire Extinguisher have been Hydraulically Pressure Tested by us as per specification and Installed at the praises of:

MS: MADHUSTHALI INSTITUTE OF TEACHER TRAINING, MADHUPUR Prop- PRINCIPAL

At- MADHUPUR, DEOGHAR -815353(Refilling)

Sr.	Description	ISI No	Qty	BIS Sr.No	HY.Test Pressure	Result
1.	ABC Type Fire Extinguisher(Multipurpose)06Kg	15683	01	MITT/06/01/05.25	35 Kg/cm ²	OK
	ABC Type Fire Extinguisher(Multipurpose)04Kg	15683	04	MITT/04/01,02,03,04/05.25	35 Kg/cm ²	OK
2.	Foam 09 Lit.(Che,Oil)	15683	00	-----	35 Kg/cm ²	OK
3.	CO2 6.5KG	15683	01	MITT/09/01/05.25	250 Kg/cm ²	OK
4.	DCP 10 Kg	15683	04	MITT/10/01,02,03,04/05.25	35 Kg/cm ²	OK
5.	Automatic Modular 05 kg	15683	00	-----	35 Kg/cm ²	--

We have found the same have been in good & Order Condition & ready for use.

Note: One year Guarantee & Validity (Seal not broken).

Note: 60% MAP

For Global Development Organization

Shashikant Crope
Authorized Signature
SHASHIKANT GOPE (B. Tech)
Hydro Test Engineer
Global Development Organization