



GLOBAL DEVELOPMENT ORGANIZATION

Fire & Safety Section

Gov of Jharkhand Reg. NO. – 755/12-13

H.O – Nangratali, Lalpur, Ranchi-834001

Branch Off- Williams Town B, Deoghar-814112

Mob, No.- 8340350646, Website: www.gdongo.org Email: globaldevorg@gmail.com

Ref. GDO/JFS/JUN 26/F.743

Date. 11.06.2026

TEST CERTIFICATE

This is to certify that the below mentioned Fire Extinguisher have been **Hydraulically Pressure Tested** by us as per specification and installed at the praisers of:

MS: MADHUSTHALI INSTITUTE OFTEACHER TRAINING, MADHUPUR Prop- PRINCIPAL

At- MADHUPUR, DEOGHAR -815353(Refilling)

Sr.	Description	ISI No	Qty	BIS Sr.No	HY.Test Pressure	Result
1.	ABC Type Fire Extinguisher(Multipurpose)06kg	15683	01	MITT/06/01/06.26	35 Kgf/cm2	OK
	ABC Type Fire Extinguisher(Multipurpose)04kg	15683	04	MITT/04/01,02,03,04/06.26	35 Kgf/cm2	OK
2.	FOAM 09 Lit.	15682	00	-----	35 Kgf/cm2	--
3.	Co2 09 Kg	15683	01	MITT/09/01/06.26	250 Kgf/Cm2	OK
4.	DCP 10 KG	15683	04	MITT/10/01,02,03,04/06.26	35 Kgf/cm2	OK
5.	Automatic Modular 05 kg	15683	00	-----	35 Kgf/cm2	--

We have found the same have been in good & Order Condition & ready for use.

Note: One year Guarantee & Validity (Seal not broken).

Note: 60% MAP

For Global Development Organization

Shashikant Gope

Authorized Signature

**SHASHIKANT GOPE (B. Tech),
Hydro Test Engineer
Global Development Organization**



GLOBAL DEVELOPMENT ORGANIZATION

Fire & Safety Section

Gov of Jharkhand Reg. NO. – 755/12-13

H.O – Nangrratoli, Lalpur, Ranchi-834001

Branch Off- Williams Town B, Deoghar-814112

Mob, No.- 8340350646, Website: www.gdongo.org Email: globaldevorg@gmail.com

Ref... G.D.O./JFS/JUN26/F-743

Date... 11.06.2026

TEST CERTIFICATE

This is to certify that the below mentioned Fire Extinguisher have been **Chemical Test** by us as per specification and installed at the praises of:

MS: MADHUSTHALI INSTITUTE OFTEACHER TRAINING, MADHUPUR Prop- PRINCIPAL

At- MADHUPUR, DEOGHAR -815353(Refilling)

Sr.	Description	ISI No	Qty	BSI Sr.No	Chemical Or Mixing	Result
1.	ABC Type Fire Extinguisher(Multipurpose)09Kg	15683	01	MITT/06/01/06.26	Môn ammonium Phosphate	OK
	ABC Type Fire Extinguisher(Multipurpose)06Kg	15683	04	MITT/04/01,02,03,04/06.26	Ammonium Sulphate,60:40	OK
2.	Foam 09 Lit.(Che,Oil)	15683	00	-----	M/F(As PerBSI Rule)	--
3.	CO2 4.5KG	15683	01	MITT/09/01/06.26	90% HARD Co2	OK
4.	DCP 09 Kg	15683	04	MITT/10/01,02,03,04/06.26	Sodium Bio – Carbonate Potassium Bio-Carbonate60:40	OK
5.	Automatic Modular 05 kg	15683	00	-----	35 Kgf/cm2	--

We have found the same have been in good & Order Condition & ready for use.

Note: One year Guarantee & Validity (Seal not broken).

Note: 60% MAP

For Global Development Organization

DK Prasad

Authorized Signature

**D. K. Prasad (Ex Raj. HIL Ltd)
CHEMIST C Test
Global Development Organization**



Fire Safety Division

Registered by Govt of Jharkhand, 755/12-13

GLOBAL DEVELOPMENT ORGANIZATION

BC (DCP Powder) ISI : 4308 CML No. : 5522661 | ABC (Powder) ISI : 14609 CML No. : 5602760
NEW Cylinder ISI : 15683 CML No. : 5522661 | HSN/SAC No. : 84241000

FIRE SAFETY CERTIFICATE

GUARANTEE REFILLING CERTIFICATE

This is to certify that the following fire extinguishers are refilled/supplied (New) by us

Certificate No. GDO/JFS/JUN26/F-743

1. ABC Type : ..06...Kg.04.Nos Sr No.04/01,02,03,04
09 01 06/01
2. DCP Type : ..09...Kg04.Nos Sr No.10/01,02,03,04
3. Mechanical Foam (AFFF) :.....Ltr.....Nos Sr No.....
4. CO₂ Type : ..4.5..Kg.01.Nos Sr No.09/01
5. Water CO₂ Type :.....Ltr.....Nos Sr No.....
6. Automatic Modular :.....Kg.....Nos Sr No.....
7. Map 60%:..... Others.....

on Dated 11-06-2026 to 10-06-2027

Certified that the MADHUSTHALI INSTITUTE OF TEACHER TRAINING

Director PRINCIPAL at MADHUPUR

P.S. MADHUPUR, Dist. DEOGHAR PIN No. 815353

(Jharkhand) have completed with the fire prevention and fire safety

instruments requirements in accordance with fire service. Validity from

Dated 11-06-2026 to 10-06-2027.



For **Global Development Organization**

Date of Issue 11.06.2026



Isha Kumari
Authorised Signatory

Registered Office : Lalpur, Ranchi - 834001 | Branch Office : Williams Town, Deoghar (Jharkhand)
Deals In : Fire Extinguisher Sale & Service, Hydrant System, We also provide CCTV &
Latest Safe Security Equipments, Agricultural Products & Stationery items.
Mob No. : 07549320103, email : globaldevorg@gmail.com